

WaterSavers[®] Criteria



WaterSavers[®]
Using Less. Returning Clean.

ALL PARTICIPANTS

- All water discharge must be routed to water treatment or a leech/septic field as permitted.
- A backflow prevention device must be installed and operable on the potable water supply.
- All spray nozzles must be inspected annually to ensure maximum efficiency of water used.
- All water-saving devices must be maintained to original or improved specifications for the conservation of water.
- Spot-free reverse osmosis concentrate (a.k.a. “reject”), if such a system is used, must be reused in the wash process.

AND



CONVEYORIZED OR IN-BAY/ROLL-OVER WASHES

Average of no more than **40 gallons** of potable/fresh water per car.



SELF-SERVICE WASHES

Maintains high-pressure wash nozzles and pump systems that use fewer than **3 gallons per minute**.